

SAFETY AND BUILDINGS DIVISION Plumbing Product Review P.O. Box 2658 Madison, Wisconsin 53701-2658

Jim Doyle, Governor Jack L. Fischer, A.I.A., Secretary

August 6, 2008

PERFECTION CORPORATION DAVID ROBISON 222 LAKE STREET MADISON OH 44057-3189

Re: Description: FITTINGS, POLYPROPYLENE Manufacturer: PERFECTION CORPORATION

Product Name: PERFECTION CLEARFLOW DIELECTRIC WATERWAY FITTING

Model Number(s): 19100, 19125, 19145, 19155, 19165, 19175, 19180, 19185, 19190, 19195, 19146P,

19149P, 191251P, 19159P, 19166P, 19169P, 19176P, 19179P, 19181P, 19186P, 19191P

AND 19196P

Product File No: 20080303

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30(4) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2013.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The product must conform to ASTM Standard F492.
- This product may be installed for the following water use(s):

a. Fixture supply connector . . . . . . . Aboveground

b. Water distribution piping . . . . . . . . Aboveground

This approval supersedes the approval issued on April 14, 2003 under product file number 20030060.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20030060.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson Plumbing Product Reviewer Phone: 608-266-6742

Fax: 608-267-9566

E-mail: Jerry.Thompson@wi.gov

SBD-10564-E (N.10/97) File Ref: 08030301.DOC